

ACE WINDOWS (NE) LTD

Unit 1, Dunston
Workshop
Railway Street
NE11 9EB

CE	
Ace Windows (NE) Ltd Unit 1 Railway Street Dunston Tyne & Wear NE11 9EB	
13	
BS EN 14351-1:2006 + A1:2010	
Double-glazed PVCu Casement Window 1700 System Intended for use not on escape route	
Resistance to wind load	Class E (2400 Pa)
Watertightness	Class 7A (300 Pa)
Dangerous substances	None
Load-bearing capacity of safety device	350n
Acoustic performance	Npd
Thermal transmittance	≤ 1.6 W/(m ² .K)
Radiation properties	Npd
Air permeability	Class 2 (300 Pa)

CE	
Ace Windows (NE) Ltd Unit 1 Railway Street Dunston Tyne & Wear NE11 9EB	
13	
BS EN 14351-1:2006 + A1:2010	
Double-glazed PVCu Residential door 1700 System Intended for use not on escape route	
Resistance to wind load	npd
Watertightness	npd)
Dangerous substances	None
Load-bearing capacity of safety device	npd
Acoustic performance	Npd
Thermal transmittance	≤ 1.8 W/(m ² .K)
Radiation properties	Npd
Air permeability	npd

CE	
Ace Windows (NE) Ltd Unit 1 Railway Street Dunston Tyne & Wear NE11 9EB	
13	
BS EN 14351-1:2006 + A1:2010	
Double-glazed PVCu Tilt 7 Turn window type 1700 System intended for use not on escape route	
Resistance to wind load	Class E (2400 Pa)
Watertightness	Class 7A (300 Pa)
Dangerous substances	None
Load-bearing capacity of safety device	npd
Acoustic performance	npd
Thermal transmittance	≤ 1.6 W/(m ² .K)
Radiation properties	Npd
Air permeability	Class 2 (300 Pa)

WER Calculator - Casement Windows - Double Glazing

Selecta Systems

Frame Profiles: Advance 70 Intermediate Internally Glazed

Reinforcement: Thermal Insert

Unit Glazing make-up: AGC - Float/ Air Planibel A 4/20/4

Spacer Bar: Hot Melt Only Thermobar

Centre pane U-Value	1.6	W/m ² .K
G Value	0.72	-
Assessment Date	19/05/2014	

This calculator is the intellectual property of Certass Limited. It may be used under license by third parties solely for the use of gaining and registering a Window Energy Rating with the Thermal Rating Register. For full details of the license to use this calculator visit www.thermalratingregister.org/calculator

Summary of Results				
U	U-f	g/Glass	AL	Thermal Rating
1.64	0.660	0.72	0.00	-19

Band: C

Range: -10 > TR ≥ -20

Reg No. AC144368
Ace Windows (NE) Ltd

This is an important document. It's been issued conforming to building regulations / control. It must be kept at the property where these products have been installed. It may be requested to be seen by building inspectors, Certass representatives.