

# Risk assessment form

Area location: Ace Windows NE		Date: 16/5/2017
Identify the hazard	Who can be harmed? *	Rank
Arson Fire/ Explosion	Employees	✓ Low
	Client staff	○
	Contractors	○
	Visitors	✓
	General public	○
	Other(s)	○
Identify the consequences in detail (that is, what type of harm or loss can occur)		
<p>Fatalities, injuries and smoke inhalation to staff and public          If asbestos present may pose a risk to Firefighters          Loss of building and loss of employment</p>		
List the existing control measures		
The site has 24/7 security		
Combustible materials are kept outside premise but this unavoidable, however a regular program is in place to remove these items which is removed by a reputable company		
Ignition sources are kept away from combustible items		
Fire risk assessments carried out and emergency evacuation plan in place		
Electric heaters are a source of ignition nad its important that these are kept away from materials		
Good housekeeping is evident in both premises		
Electrical equipment in the unit drops to 110 on equipment		
Extinguishers are in place		
Actions required (list any additional actions that may be required to further reduce risks)		
Ensure extinguishers are tested		
Post box always present a risk of Arson		
Recommend relevant portable electrical equipment is inspected and logged as satisfactory		

Risk assessment carried out by R Pyne

16/5/2017

Overall risk presented (after control measures are implemented)

8